

## Errata for the 2007 Oregon Fire Code

Last update December 6, 2007

~~Strikethrough~~ text represents deleted language.

Underlined text represents added language.

- 1) On page 68, Table 803.3 there should be footnotes k and m at the end of the title. The letter m is missing. Please pencil it in.
- 2) On page 238, Section 2404.17.2 part of the paragraph was not printed. Please cutout the following paragraph and place it over the existing.

**2404.17.2 Flammable and combustible liquid storage.**

Flammable and combustible liquids shall be stored outside in an approved manner not less than 50 feet (15 240 mm) from tents, canopies or membrane structures. Storage shall be in accordance with Chapter 34.

- 3) **1027.1.1 Determining the adequacy of the means of egress.** In determining the adequacy of the means of egress, as required by OAR 837-04100050(2)(d), the fire code official may be guided by the requirement specified in Sections ~~1026.2~~ 1027.2 through ~~1026.21~~ 1027.21.