



800 NE Oregon Street, Suite 465, Portland OR 97232

Voice: (971) 673-0540

Fax: (971) 673-0556

TTY: (971) 673-0372

Facilities Planning & Safety Unit

http://www.healthoregon.org/fps

mailbox.fps@state.or.us

Site Inspection Check List for:

Hospital Licensed Outpatient Clinics - OAR 333-535-0086

PR# _____ Date: _____ Inspector: _____

Provider: _____

Project: _____

Address: _____

Present at Site Inspection: _____

Intended Occupancy Date: _____

Required PRIOR to Approved Inspection:

RECEIVED?

YES NO NA

Certificate of Occupancy (CO) from governing jurisdiction

MEP Close-Out verification (if required)

SITE INSPECTION:

INTERIOR = Verify that the facility has installed:

OVERALL:

YES NO NA

This rule applies to Outpatient Clinics that are under the license of a general hospital and either physically connected or in freestanding, satellite locations, as defined by OAR 333-500-0010 (46)(a)

OAR 333-535-0085 shall apply except as follows:

Entry shall be disabled accessible 333-535-0086 (1)(a)

Conditions where public toilets rooms do not exist, then patient toilets may be used for public when addressed by the the Hospital's functional program. 333-535-0086 (1)(d)

- For Outpatient Clinics where only Counseling or Non-Clinical services are provided, wheelchair storage space(s), examination rooms(s), treatment room(s), drug distribution station, clean workroom or clean holding room, and soiled workroom or soiled holding room may be omitted. 333-535-0086 (3)

A patient care unit in a satellite location that provides extended outpatient stay services for patients that do not require hospitalization, beyond an average length of stay of 24 hours, must, notwithstanding sections (1) through (3) of this rule, comply with: 333-535-0086 (4)

- OAR 333-535-0025 Medical/Surgical Patient Care Unit. 333-535-0086 (4)(a)

- OAR 333-535-0290 Elevators. 333-535-0086 (4)(b)

- OAR 333-535-0300 including OAR 333-535-0300 (3)(d) where inpatient standards will apply. 333-535-0086 (4)(c)

- OAR 333-535-0310 including OAR 333-535-0310 (4)(c)(A) through (d) where inpatient standards will apply. 333-535-0086 (4)(d)

- OAR 333-535-0310 (8)(b) except that the minimum number of hours to operate emergency electric services shall be equivalent to the maximum expected length of patients' stay specified in the functional program. 333-535-0086 (4)(e)